

Natural Ventilation of a Short Road Tunnel - Application of FDS+EVAC

Katie McQuade-Jones and Matt Bilson

WSP USA

DECK PARK OVERBUILD



DECK PARK OVERBUILD



CODE REQUIREMENTS: NFPA 502

Section 11.1.1:

Emergency ventilation shall not be required in tunnels less than 3280 feet in length, where it can be shown by an engineering analysis that the level of safety provided by a mechanical ventilation system is equaled or exceeded by enhancing the means of egress or the use of natural ventilation.

CODE REQUIREMENTS: NFPA 502

Section 11.1.1:

Emergency ventilation shall not be required in tunnels less than 3280 feet in length, where it can be shown by an engineering analysis that the level of safety provided by a mechanical ventilation system is equaled or exceeded by enhancing the means of egress or the use of natural ventilation.

How do we show equivalent level of safety quantitatively?

EXISTING SHORT TUNNELS

Name	Length m (ft.)	Urban /rural	Traffic	Year	Ventilation
I5 Tunnel, Seattle, WA	167 (547)	U	Uni	1988	Natural
Dyer Avenue, New York	168 (550)	U	Bi	*	Mechanical
Rockville, Intercounty Conn, Maryland	195 (640)	R	Bi	2010	Natural
Pasadena, I210, California	271 (889)	U	Uni	2003	Natural
College Avenue Tunnel, Milwaukee, WI	277 (910)	U	Uni	2010	Mechanical

DEFINING LEVEL OF SAFETY

NFPA 502 Section 11.2.2:

In all cases, the desired goal shall be **to provide an evacuation path for motorists** who are exiting from the tunnel and to facilitate fire-fighting operations.

DEFINING LEVEL OF SAFETY

NFPA 502 Section 11.2.2:

In all cases, the desired goal shall be **to provide an evacuation path for motorists** who are exiting from the tunnel and to facilitate fire-fighting operations.

— *Use tenable egress path criteria to demonstrate safety*

TENABLE EGRESS PATH CRITERIA

- Traditional methods use visibility > 10 m to define tenability
- For some fire scenarios in short tunnels, might not be able to show visibility of 10 m (e.g. fuel tanker fire)



TENABLE EGRESS PATH CRITERIA

- Traditional methods use visibility > 10 m to define tenability
- For some fire scenarios in short tunnels, might not be able to show visibility of 10 m (e.g. fuel tanker fire)




- Fractional effective dose (FED) and fractional irritant concentration method
- Track FED of toxic gases and heat exposure
- Track FIC of toxic gases
- Set criteria so more susceptible occupants can self evacuate


TENABLE EGRESS PATH CRITERIA

- Toxic gas FED based on Purser's equation (used in EVAC)
- Heat exposure FED calculated based on NFPA 502 Annex B equations
 - *Output visibility and temperature profiles to calculate this for a theoretical occupant*
- To be considered a passing result:
 - *Toxic gas FED < 0.3*
 - *Heat exposure FED < 0.3*
 - *Toxic gas FIC < 0.3*

SCENARIO SCHEMATIC



SCENARIO SCHEMATIC




13

- Dangerous goods vehicle (DGV) fires versus heavy goods vehicle (HGV) fires
- Quantity of egress doors
- Length of tunnel (600 ft. and 1000 ft.)
- 2 lane vs. 6 lane tunnels

FIRE SCENARIO

Fire heat release rate curves




COMBUSTION REACTION

- Emissions from an experimental vehicle fire used as a basis (Lonnermark and Blomqvist)
- Reaction included: CO, NO₂, HCN, HCl, SO₂, C₃H₄O, and CH₂O, soot
- All species included in FDS+EVAC FED/FIC calculation

RESULTS SUMMARY


Length (m)	Lanes	Design fire	Provisions to meet NPFA 502 with natural ventilation
180	2	HGV	Portal egress
180	2	DGV	Additional egress doors
180	6	DGV	Portal egress
305	2	HGV	Additional egress doors
305	6	DGV	Additional egress doors

VISIBILITY AT 2.4 M ABOVE ROADWAY




- 180 m tunnel, HGV fire
- Slice taken at 310 seconds (last occupant exits)

SECTION VIEW OF TEMPERATURE




Temperature (°C)



- 180 m tunnel, HGV fire
- Slice taken at 310 seconds (last occupant exits)

VISIBILITY AT 2.4 M ABOVE ROADWAY



— 180 m tunnel, DGV fire

— Slice taken at 335 seconds (last occupant exits)

RESULTS SUMMARY

- Results are consistent with recent work by Purser, suggesting that occupants can move through visibilities of 2 m for 20-60 minutes
- Can use this quantitative approach to form a basis for approval by the authority having jurisdiction (AHJ)

SIMULATIONS

Case number	Ventilation	Egress doors	FHRR (MW)	Tunnel length	Lanes	Max. FED, toxic gases	Max. FED, heat	Max. FIC	Pass/fail
FEM-01-01	Natural	0	300	180	2	0.081	1.00	1.00	Fail
FEM-01-02	Mechanical	0	300	180	2	0.003	0.02	0.20	Pass
FEM-01-03	Natural	2	300	180	2	0.013	0.00	0.05	Pass
FEM-01-04	Natural	0	140	180	2	0.002	0.01	0.05	Pass
FEM-01-05	Mechanical	0	140	180	2	0.002	0.01	0.05	Pass
FEM-01-06	Natural	2	140	180	2	0.001	0.00	0.05	Pass
FEM-01-07	Natural	0	300	180	6	0.003	0.02	0.20	Pass
FEM-01-08	Mechanical	0	300	180	6	0.001	0.01	0.10	Pass
FEM-01-10	Natural	0	140	305	2	0.012	0.06	0.35	Fail
FEM-01-11	Mechanical	0	140	305	2	0.002	0.01	0.05	Pass
FEM-01-12	Natural	0	300	305	6	0.067	0.20	0.55	Fail
FEM-01-13	Mechanical	0	300	305	6	0.001	0.01	0.10	Pass